

## Attachment L - Results Summary Lead in Water Samples

School Name: **Amsterdam Elementary School**

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
AES-HGYM-WC1	AES-30-1118-01	WF; hallway across from Kitchen; higher unit	ND	No
AES-HGYM-WC2	AES-30-1118-02	WF; hallway across from Kitchen; lower unit	ND	No
AES-KITCHEN-FP	AES-30-1118-03	Sink faucet; Kitchen; Food Prep	1.53	No
AES-1-STAFF-WR-TF	AES-30-1118-04	Sink faucet; Staff Work Room/Copy Room	1.03	No
AES-1-1-SB	AES-30-1118-05	Bubbler on Sink; Room 1	ND	No
AES-1-1-CF	AES-30-1118-06	Sink faucet; Room 1	ND	No
AES-1-H1-WC1	AES-30-1118-07	WF; hallway at Room 1; lower unit (L)	ND	No
AES-1-H1-WC2	AES-30-1118-08	WF; hallway at Room 1; upper unit (R)	ND	No
AES-1-2-SB	AES-30-1118-09	Bubbler on Sink; Room 2	ND	No
AES-1-2-CF	AES-30-1118-10	Sink faucet: Room 2	ND	No
AES-1-3-SB	AES-30-1118-11	Bubbler on Sink; Room 3	ND	No
AES-1-3-CF	AES-30-1118-12	Sink faucet: Room 3	ND	No
AES-1-4-SB	AES-30-1118-13	Bubbler on Sink; Room 4	1.28	No
AES-1-4-CF	AES-30-1118-14	Sink faucet: Room 4	ND	No
AES-1-KGA-SB	AES-30-1118-15	Bubbler on Sink; Room	ND	No
AES-1-KGA-CF	AES-30-1118-16	Sink faucet: Room	ND	No
AES-1-5-SB	AES-30-1118-17	Bubbler on Sink; Room 5	ND	No
AES-1-5-CF	AES-30-1118-18	Sink faucet: Room 5	6.13	No
AES-1-KGB-SB	AES-30-1118-19	Bubbler on Sink; Kindergarten B	ND	No
AES-1-KGB-CF	AES-30-1118-20	Sink faucet; Kindergarten B	ND	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported

## Attachment L - Results Summary Lead in Water Samples

School Name: **Amsterdam Elementary School**

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
AES-1-6-SB	AES-30-1118-21	Bubbler on Sink; Room 6	ND	No
AES-1-6-CF	AES-30-1118-22	Sink faucet: Room 6	ND	No
AES-1-LIBRARY-TF	AES-30-1118-23	Sink faucet; Library office	ND	No
AES-1-7-SB	AES-30-1118-24	Bubbler on Sink; Room 7	ND	No
AES-1-7-CF	AES-30-1118-25	Sink faucet: Room 7	ND	No
AES-1-8-SB	AES-30-1118-26	Bubbler on Sink; Room 8	ND	No
AES-1-8-CF	AES-30-1118-27	Sink faucet: Room 8	ND	No
AES-1-14-SB	AES-30-1118-28	Bubbler on Sink; Room 14	3.03	No
AES-1-14-CF	AES-30-1118-29	Sink faucet: Room 14	ND	No
AES-1-13-SB	AES-30-1118-30	Bubbler on Sink; Room 13	1.16	No
AES-1-13-CF	AES-30-1118-31	Sink faucet: Room 13	ND	No
AES-1-H13-WC1	AES-30-1118-32	WF; hallway at Room 13; higher unit	ND	No
AES-1-H13-WC2	AES-30-1118-33	WF; hallway at Room 13; lower unit	ND	No
AES-1-9-SB	AES-30-1118-34	Bubbler on Sink; Room 9	ND	No
AES-1-9-CF	AES-30-1118-35	Sink faucet: Room 9	ND	No
AES-1-12-SB	AES-30-1118-36	Bubbler on Sink; Room 12	1.37	No
AES-1-12-CF	AES-30-1118-37	Sink faucet: Room 12	1.12	No
AES-1-10-SB	AES-30-1118-38	Bubbler on Sink; Room 10	nd	No
AES-1-10-CF	AES-30-1118-39	Sink faucet: Room 10	2.06	No
AES-1-11-SB	AES-30-1118-40	Bubbler on Sink; Room 11	1.09	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported

## Attachment L - Results Summary Lead in Water Samples

School Name: **Amsterdam Elementary School**

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
AES-1-11-CF	AES-30-1118-41	Sink faucet: Room 11	ND	No
AES-1-FACULTY-TF	AES-30-1118-42	Sink faucet; Staff Dining Room	ND	No
AES-1-MO-TF	AES-30-1118-43	Sink faucet; Main Office; Work Room	1.07	No
AES-1-NURSE-CF	AES-30-1118-44	Sink faucet; Nurse's Office; Exam Room	1.79	No
AES-1-NURSE-NBR	AES-30-1118-45	Sink faucet; Nurse's Office; restroom	1.34	No
AES-1-15-SB	AES-30-1118-46	Bubbler on Sink; Room 15	1.85	No
AES-1-15-CF	AES-30-1118-47	Sink faucet: Room 15	3.93	No
AES-1-H16-WC1	AES-30-1118-48	WF; hallway across from Room 16; higher unit	ND	No
AES-1-H16-WC2	AES-30-1118-49	WF; hallway across from Room 16; lower unit	ND	No
AES-1-17-SB	AES-30-1118-50	Bubbler on Sink; Room 17	1.32	No
AES-1-17-CF	AES-30-1118-51	Sink faucet: Room 17	ND	No
AES-1-24-SB	AES-30-1118-52	Bubbler on Sink; Room 24	ND	No
AES-1-24-CF	AES-30-1118-53	Sink faucet: Room 24	ND	No
AES-1-23-SB	AES-30-1118-54	Bubbler on Sink; Room 23	ND	No
AES-1-23-CF	AES-30-1118-55	Sink faucet: Room 23	2.14	No
AES-1-18-SB	AES-30-1118-56	Bubbler on Sink; Room 18	ND	No
AES-A-18-CF	AES-30-1118-57	Sink faucet: Room 18	ND	No
AES-1-19-SB	AES-30-1118-58	Bubbler on Sink; Room 19	1.02	No
AES-1-19-CF	AES-30-1118-59	Sink faucet: Room 19	1.23	No
AES-1-22-SB	AES-30-1118-60	Bubbler on Sink; Room 22	ND	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported

