

Attachment L - Results Summary Lead in Water Sample

School Name: **Auten Road Intermediate School**

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
ARIS-1-KITCHEN-FP1	ARIS-1130-01	Sink faucet; Kitchen; Food Prep	ND	No
ARIS-1-KITCHEN-FP2	ARIS-1130-02	Sink faucet; Kitchen; Food Prep	1.53	No
ARIS-1-KITCHEN-FP3	ARIS-1130-03	Sink faucet; serving area	ND	No
ARIS-1-KITCHEN-IM	ARIS-1130-04	Ice Machine; Kitchen	ND	No
ARIS-1-KITCHEN-KT	ARIS-1130-05	Kettle faucet; Kitchen	10.9	No
ARIS-1-LIB309-TF	ARIS-1130-06	Sink faucet; Library	ND	No
ARIS-1-MOFWR-TF	ARIS-1130-07	Sink faucet; Main Office Work Room	1.29	No
ARIS-1-MO-PRINTER-TF	ARIS-1130-08	Sink faucet; Main Office Printer Room	ND	No
ARIS-1-NURSE-NS1	ARIS-1130-09	Sink faucet; Nurse main area	1.13	No
ARIS-1-NEXAM-NS2	ARIS-1130-10	Sink faucet; Nurse Exam Room	ND	No
ARIS-1-NURSE-NBR	ARIS-1130-11	Sink faucet; Nurse bathroom	ND	No
ARIS-1-338-SB	ARIS-1130-14	Bubbler on sink; Room 338	ND	No
ARIS-1-338-CF	ARIS-1130-15	Sink faucet; Room 338	9.32	No
ARIS-1-H347-WC1	ARIS-1130-16	WF; hallway by Room 338	ND	No
ARIS-1-H347-WC2	ARIS-1130-17	WF; hallway by Room 338	ND	No
ARIS-1-343-SB	ARIS-1130-18	Bubbler on sink; Room 343	ND	No
ARIS-1-343-CF	ARIS-1130-19	Sink faucet; Room 343	4.24	No
ARIS-1-344-SB	ARIS-1130-20	Bubbler on sink; Room 344	ND	No
ARIS-1-344-CF	ARIS-1130-21	Sink faucet; Room 344	ND	No
ARIS-1-201-SB	ARIS-1130-22	Bubbler on sink; Room 201	ND	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Sample

School Name: **Auten Road Intermediate School**

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
ARIS-1-201-CF	ARIS-1130-23	Sink faucet; Room 201	ND	No
ARIS-1-216-SB	ARIS-1130-24	Bubbler on sink; Room 216	ND	No
ARIS-1-216-CF	ARIS-1130-25	Sink faucet; Room 216	ND	No
ARIS-1-202-SB	ARIS-1130-26	Bubbler on sink; Room 202	ND	No
ARIS-1-202-CF	ARIS-1130-27	Sink faucet; Room 202	ND	No
ARIS-1-215-SB	ARIS-1130-28	Bubbler on sink; Room 215	ND	No
ARIS-1-215-CF	ARIS-1130-29	Sink faucet; Room 215	ND	No
ARIS-1-203-SB	ARIS-1130-30	Bubbler on sink; Room 203	ND	No
ARIS-1-203-CF	ARIS-1130-31	Sink faucet; Room 203	ND	No
ARIS-1-214-SB	ARIS-1130-32	Bubbler on sink; Room 214	ND	No
ARIS-1-214-CF	ARIS-1130-33	Sink faucet; Room 214	ND	No
ARIS-1-207-SB	ARIS-1130-34	Bubbler on sink; Room 207	ND	No
ARIS-1-207-CF	ARIS-1130-35	Sink faucet; Room 207	1.34	No
ARIS-1-208-SB	ARIS-1130-36	Bubbler on sink; Room 208	ND	No
ARIS-1-208-CF	ARIS-1130-37	Sink faucet; Room 208	5	No
ARIS-1-211-SB	ARIS-1130-38	Bubbler on sink; Room 211	ND	No
ARIS-1-211-CF	ARIS-1130-39	Sink faucet; Room 211	ND	No
ARIS-1-209-SB	ARIS-1130-40	Bubbler on sink; Room 209	ND	No
ARIS-1-209-CF	ARIS-1130-41	Sink faucet; Room 209	ND	No
ARIS-1-210-SB	ARIS-1130-42	Bubbler on sink; Room 210	ND	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Sample

School Name: **Auten Road Intermediate School**

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
ARIS-1-210-CF	ARIS-1130-43	Sink faucet; Room 210	ND	No
ARIS-1-141-CF	ARIS-1130-44	Sink faucet; Room 141	2.02	No
ARIS-1-CUSTST-TF	ARIS-1130-45	Sink faucet; Custodial Office	ND	No
ARIS-1-127-SB	ARIS-1130-46	Bubbler on sink; Room 127	ND	No
ARIS-1-127-CF	ARIS-1130-47	Sink faucet; Room 127	ND	No
ARIS-1-128-SB	ARIS-1130-48	Bubbler on sink; Room 128	ND	No
ARIS-1-128-CF	ARIS-1130-49	Sink faucet; Room 128	1.11	No
ARIS-1-H127-WC1	ARIS-1130-50	WF; hallway by Room 127	ND	No
ARIS-1-H127-WC2	ARIS-1130-51	WF; hallway by Room 127	ND	No
ARIS-1-132-SB	ARIS-1130-52	Bubbler on sink; Room 132	40.5	Yes
ARIS-1-132-CF	ARIS-1130-53	Sink faucet; Room 132	ND	No
ARIS-1-129-SB	ARIS-1130-54	Bubbler on sink; Room 129	ND	No
ARIS-1-129-CF	ARIS-1130-55	Sink faucet; Room 129	ND	No
ARIS-1-131-SB	ARIS-1130-56	Bubbler on sink; Room 131	ND	No
ARIS-1-131-CF	ARIS-1130-57	Sink faucet; Room 131	ND	No
ARIS-1-130-SB	ARIS-1130-58	Bubbler on sink; Room 130	ND	No
ARIS-1-130-CF	ARIS-1130-59	Sink faucet; Room 130	ND	No
ARIS-1-139-SB	ARIS-1130-60	Bubbler on sink; Room 139	ND	No
ARIS-1-139-CF	ARIS-1130-61	Sink faucet; Room 139	ND	No
ARIS-1-134-SB	ARIS-1130-62	Bubbler on sink; Room 134	ND	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Sample

School Name: **Auten Road Intermediate School**

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
ARIS-1-134-CF	ARIS-1130-63	Sink faucet; Room 134	ND	No
ARIS-1-138-SB	ARIS-1130-64	Bubbler on sink; Room 138	ND	No
ARIS-1-138-CF	ARIS-1130-65	Sink faucet; Room 138	1.68	No
ARIS-1-135-SB	ARIS-1130-66	Bubbler on sink; Room 135	ND	No
ARIS-1-135-CF	ARIS-1130-67	Sink faucet; Room 135	ND	No
ARIS-1-137-SB	ARIS-1130-68	Bubbler on sink; Room 137	ND	No
ARIS-1-137-CF	ARIS-1130-69	Sink faucet; Room 137	1.06	No
ARIS-1-136-SB	ARIS-1130-70	Bubbler on sink; Room 136	1.44	No
ARIS-1-136-CF	ARIS-1130-71	Sink faucet; Room 136	ND	No
ARIS-1-106-SB	ARIS-1130-72	Bubbler on sink; Room 106	ND	No
ARIS-1-106-CF	ARIS-1130-73	Sink faucet; Room 106	ND	No
ARIS-1-115-SB	ARIS-1130-74	Bubbler on sink; Room 115	ND	No
ARIS-1-115-CF	ARIS-1130-75	Sink faucet; Room 115	ND	No
ARIS-1-105-SB	ARIS-1130-76	Bubbler on sink; Room 105	ND	No
ARIS-1-105-CF	ARIS-1130-77	Sink faucet; Room 105	ND	No
ARIS-1-118-SB	ARIS-1130-78	Bubbler on sink; Room 118	ND	No
ARIS-1-118-CF	ARIS-1130-79	Sink faucet; Room 118	1.19	No
ARIS-1-104-SB	ARIS-1130-80	Bubbler on sink; Room 104	ND	No
ARIS-1-104-CF	ARIS-1130-81	Sink faucet; Room 104	ND	No
ARIS-1-119-SB	ARIS-1130-82	Bubbler on sink; Room 119	ND	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Sample

School Name: **Auten Road Intermediate School**

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
ARIS-1-119-CF	ARIS-1130-83	Sink faucet; Room 119	ND	No
ARIS-1-101-SB	ARIS-1130-84	Bubbler on sink; Room 101	ND	No
ARIS-1-101-CF	ARIS-1130-85	Sink faucet; Room 101	1.12	No
ARIS-1-101-BRS	ARIS-1130-86	Sink faucet; Room 101 Bathroom	ND	No
ARIS-1-122-SB	ARIS-1130-87	Bubbler on sink; Room 122	ND	No
ARIS-1-122-CF	ARIS-1130-88	Sink faucet; Room 122	ND	No
ARIS-1-122-BRS	ARIS-1130-89	Sink faucet; Room 122 Bathroom	ND	No
ARIS-1-113-SB	ARIS-1130-90	Bubbler on sink; Room 113	2.2	No
ARIS-1-113-CF	ARIS-1130-91	Sink faucet; Room 113	ND	No
ARIS-1-112-SB	ARIS-1130-92	Bubbler on sink; Room 112	1.22	No
ARIS-1-112-CF	ARIS-1130-93	Sink faucet; Room 112	1.19	No
ARIS-1-108-SB	ARIS-1130-94	Bubbler on sink; Room 108	ND	No
ARIS-1-108-CF	ARIS-1130-95	Sink faucet; Room 108	ND	No
ARIS-1-109-SB	ARIS-1130-96	Bubbler on sink; Room 109	2.41	No
ARIS-1-109-CF	ARIS-1130-97	Sink faucet; Room 109	ND	No
ARIS-1-111-SB	ARIS-1130-98	Bubbler on sink; Room 111	1.5	No
ARIS-1-111-CF	ARIS-1130-99	Sink faucet; Room 111	ND	No
ARIS-1-301-SB	ARIS-1130-100	Bubbler on sink; Room 301	3.25	No
ARIS-1-301-CF	ARIS-1130-101	Sink faucet; Room 301	1.52	No
ARIS-1-ENTRANCE-WC1	ARIS-1130-102	WF; hallway by main entrance	ND	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Sample

School Name: **Auten Road Intermediate School**

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
ARIS-1-ENTRANCE-WC2	ARIS-1130-103	WF; hallway by main entrance	ND	No
ARIS-2-222-SB	ARIS-1130-106	Bubbler on sink; Room 222	ND	No
ARIS-2-222-CF	ARIS-1130-107	Sink faucet; Room 222	ND	No
ARIS-2-221-SB	ARIS-1130-108	Bubbler on sink; Room 221	ND	No
ARIS-2-221-CF	ARIS-1130-109	Sink faucet; Room 221	1	No
ARIS-2-237-SB	ARIS-1130-110	Bubbler on sink; Room 237	2.39	No
ARIS-2-237-CF	ARIS-1130-111	Sink faucet; Room 237	8.55	No
ARIS-2-220-SB	ARIS-1130-112	Bubbler on sink; Room 220	ND	No
ARIS-2-220-CF	ARIS-1130-113	Sink faucet; Room 220	ND	No
ARIS-2-240-TF	ARIS-1130-114	Sink faucet; Room 240 Staff Dining	ND	No
ARIS-2-H223-WC1	ARIS-1130-115	WF; hallway by Room 223	ND	No
ARIS-2-H223-WC2	ARIS-1130-116	WF; hallway by Room 223	ND	No
ARIS-2-224-SB	ARIS-1130-117	Bubbler on sink; Room 224	ND	No
ARIS-2-224-CF	ARIS-1130-118	Sink faucet; Room 224	ND	No
ARIS-2-228-SB	ARIS-1130-119	Bubbler on sink; Room 228	ND	No
ARIS-2-228-CF	ARIS-1130-120	Sink faucet; Room 228	ND	No
ARIS-2-225-SB	ARIS-1130-121	Bubbler on sink; Room 225	ND	No
ARIS-2-225-CF	ARIS-1130-122	Sink faucet; Room 225	ND	No
ARIS-2-227-SB	ARIS-1130-123	Bubbler on sink; Room 227	ND	No
ARIS-2-227-CF	ARIS-1130-124	Sink faucet; Room 227	ND	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Sample

School Name: **Auten Road Intermediate School**

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
ARIS-2-226-SB	ARIS-1130-125	Bubbler on sink; Room 226	ND	No
ARIS-2-226-CF	ARIS-1130-126	Sink faucet; Room 226	ND	No
ARIS-2-230-SB	ARIS-1130-127	Bubbler on sink; Room 230	ND	No
ARIS-2-230-CF	ARIS-1130-128	Sink faucet; Room 230	ND	No
ARIS-2-235-SB	ARIS-1130-129	Bubbler on sink; Room 235	ND	No
ARIS-2-235-CF	ARIS-1130-130	Sink faucet; Room 235	ND	No
ARIS-2-231-SB	ARIS-1130-131	Bubbler on sink; Room 231	ND	No
ARIS-2-231-CF	ARIS-1130-132	Sink faucet; Room 231	ND	No
ARIS-2-234-SB	ARIS-1130-133	Bubbler on sink; Room 234	ND	No
ARIS-2-234-CF	ARIS-1130-134	Sink faucet; Room 234	1.33	No
ARIS-2-232-SB	ARIS-1130-135	Bubbler on sink; Room 232	ND	No
ARIS-2-232-CF	ARIS-1130-136	Sink faucet; Room 232	ND	No
ARIS-2-233-SB	ARIS-1130-137	Bubbler on sink; Room 233	ND	No
ARIS-2-233-CF	ARIS-1130-138	Sink faucet; Room 233	ND	No
QC BLANK	ARIS-1130-139	DI Blank	ND	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported