

## Attachment L - Results Summary Lead in Water Samples

School Name: Sunnymeade Elementary School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
SES-1-H7-DW	SES-30-1118-01	WF; hallway at Teachers Work Room	1.06	No
SES-1-8-SB	SES-30-1118-02	Bubbler on sink; Room 8	1.43	No
SES-1-8-CF	SES-30-1118-03	Sink faucet; Room 8	2.45	No
SES-1-7-CF	SES-30-1118-04	Sink faucet; Room 7	2.47	No
SES-1-6-CF	SES-30-1118-05	Sink faucet; Room 6	4.47	No
SES-1-5-CF	SES-30-1118-06	Sink faucet; Room 5	5.17	No
SES-1-4-SB	SES-30-1118-07	Bubbler on sink; Room 4	ND	No
SES-1-4-CF	SES-30-1118-08	Sink faucet; Room 4	2.76	No
SES-1-3-SB	SES-30-1118-09	Bubbler on sink; Room 3	ND	No
SES-1-3-CF	SES-30-1118-10	Sink faucet; Room 3	1.43	No
SES-1-1-DW	SES-30-1118-11	WF; Room 1 on wall next to sink	11.2	No
SES-1-1-CF3	SES-30-1118-12	Sink faucet; Room 1	2.35	No
SES-1-1-SB1	SES-30-1118-13	Bubbler on sink; Room 1 hallway corner	3.4	No
SES-1-1-CF1	SES-30-1118-14	Sink faucet; Room 1 hallway corner	2.72	No
SES-1-1-SB2	SES-30-1118-15	Bubbler on sink; Room 1 exterior corner	4.81	No
SES-1-1-CF2	SES-30-1118-16	Sink faucet; Room 1 exterior corner	2.25	No
SES-1-2-DW	SES-30-1118-17	WF; Room 2 on wall next to sink	8.05	No
SES-1-2-CF3	SES-30-1118-18	Sink faucet; Room 2	2.26	No
SES-1-2-SB1	SES-30-1118-19	Bubbler on sink; Room 2	2.71	No
SES-1-2-CF1	SES-30-1118-20	Sink faucet; Room 2	2.83	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported

## Attachment L - Results Summary Lead in Water Samples

School Name: Sunnymeade Elementary School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
SES-1-2-SB2	SES-30-1118-21	Bubbler on sink; Room 2	3.04	No
SES-1-2-CF2	SES-30-1118-22	Sink faucet; Room 2	5.35	No
SES-1-MO-TF	SES-30-1118-23	Sink faucet; Main Office	2.33	No
SES-1-NURSE-NS	SES-30-1118-24	Sink faucet; Nurse Office main area	1.02	No
SES-1-NURSE-WC	SES-30-1118-25	WF; Nurse Office main area	ND	No
SES-1-NEXAM-NS	SES-30-1118-26	Sink faucet; Nurse Exam Room	5.95	No
SES-1-10-CF	SES-30-1118-27	Sink faucet; Room 10	1.95	No
SES-1-12-CF	SES-30-1118-28	Sink faucet; Room 12	5.25	No
SES-1-13-CF	SES-30-1118-29	Sink faucet; Room 13	3.43	No
SES-1-14-SB	SES-30-1118-30	Bubbler on sink; Room 14	18.2	Yes
SES-1-14-CF	SES-30-1118-31	Sink faucet; Room 14	17.8	Yes
SES-1-15-SB	SES-30-1118-32	Bubbler on sink; Room 15	5.44	No
SES-1-15-CF	SES-30-1118-33	Sink faucet; Room 15	3.39	No
SES-1-16-CF	SES-30-1118-34	Sink faucet; Room 16	4.16	No
SES-1-FACULTY DINING-TF	SES-30-1118-35	Sink faucet; Faculty Dining Room	1.3	No
SES-1-KITCHEN-FP	SES-30-1118-36	Sink faucet; Kitchen	1.43	No
SES-1-25-SB	SES-30-1118-37	Bubbler on sink; Room 25	ND	No
SES-1-25-CF	SES-30-1118-38	Sink faucet; Room 25	1.55	No
SES-1-24-SB	SES-30-1118-39	Bubbler on sink; Room 24	2.35	No
SES-1-24-CF	SES-30-1118-40	Sink faucet; Room 24	5.66	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported

## Attachment L - Results Summary Lead in Water Samples

School Name: Sunnymeade Elementary School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
SES-1-22-SB	SES-30-1118-41	Bubbler on sink; Room 22	ND	No
SES-1-22-CF	SES-30-1118-42	Sink faucet; Room 22	1.34	No
SES-1-21-SB	SES-30-1118-43	Bubbler on sink; Room 21	ND	No
SES-1-21-CF	SES-30-1118-44	Sink faucet; Room 21	2.6	No
SES-1-19-CF	SES-30-1118-45	Sink faucet; Room 19	7.44	No
SES-1-17-SB	SES-30-1118-46	Bubbler on sink; Room 17	ND	No
SES-1-17-CF	SES-30-1118-47	Sink faucet; Room 17	2.52	No
SES-1-20-SB	SES-30-1118-48	Bubbler on sink; Room 20	ND	No
SES-1-20-CF	SES-30-1118-49	Sink faucet; Room 20	3.6	No
SES-1-18-SB	SES-30-1118-50	Bubbler on sink; Room 18	1.31	No
SES-1-18-CF	SES-30-1118-51	Sink faucet; Room 18	1.95	No
SES-1-HLMC-WC	SES-30-1118-52	WF; hallway by gym	ND	No
QC BLANK	SES-30-1118-53	DI Blank	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)  
 ND = None Detected; NR = Not Reported