

Attachment L - Results Summary Lead in Water Sample

School Name: Sunnymeade Elementary School *(12-20-17 data, only)*

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
SES-1-10-SB	SES-13-1220-01	Bubbler on sink; Room 10	189	Yes
SES-1-12-SB	SES-13-1220-02	Bubbler on sink; Room 12	45.7	Yes
SES-1-13-SB	SES-13-1220-03	Bubbler on sink; Room 13	229	Yes
SES-1-16-SB	SES-13-1220-04	Bubbler on sink; Room 16	3.99	No
SES-HCAF-DW	SES-13-1220-05	WF; hallway by cafeteria	1.49	No
SES-1-7-SB	SES-13-1220-06	Bubbler on sink; Room 7	4.37	No
SES-1-5-SB	SES-13-1220-07	Bubbler on sink; Room 5	108	Yes
SES-1-6-SB	SES-13-1220-08	Bubbler on sink; Room 6	15.1	No
QC BLANK	SES-13-1220-09	DI Blank	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported