



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Tom Pruno
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

1/4/2018

Phone: (856) 616-9516
Fax: (586) 616-9517

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/21/2017. The results are tabulated on the attached data pages for the following client designated project:

HTPS - Woodfern Elementary School - PR-171031-1172

The reference number for these samples is EMSL Order #011710093. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011710093

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 12/21/17 2:50 PM

Project: **HTPS - Woodfern Elementary School - PR-171031-1172****Analytical Results**

Client Sample Description WES-13-1221-01
 WES-1-112-SB; Bubbler on Sink; Room 112
Collected: 12/21/2017 **Lab ID:** 011710093-0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.2	1.00	µg/L	12/26/2017	JW	12/26/2017	JW

Client Sample Description WES-13-1221-02
 WES-1-120-SB; Bubbler on Sink; Room 120
Collected: 12/21/2017 **Lab ID:** 011710093-0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/26/2017	JW	12/26/2017	JW

Client Sample Description WES-13-1221-03
 WES-1-113-SB; Bubbler on Sink; Room 113
Collected: 12/21/2017 **Lab ID:** 011710093-0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.1	1.00	µg/L	12/26/2017	JW	12/26/2017	JW

Client Sample Description WES-13-1221-04
 WES-1-117-SB; Bubbler on Sink; Room 117
Collected: 12/21/2017 **Lab ID:** 011710093-0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.8	1.00	µg/L	12/26/2017	JW	12/26/2017	JW

Client Sample Description WES-13-1221-05
 WES-1-115-SB; Bubbler on Sink; Room 115
Collected: 12/21/2017 **Lab ID:** 011710093-0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/26/2017	JW	12/26/2017	JW

Client Sample Description WES-13-1221-06
 QC Blank
Collected: 12/21/2017 **Lab ID:** 011710093-0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/26/2017	JW	12/26/2017	JW

Definitions:

ND - indicates that the analyte was not detected at the reporting limit
 RL - Reporting Limit (Analytical)