Attachment L - Results Summary Lead in Water Sample

School Name: Woodfern Elementary School *(12-21-17 data, only)*

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
WES-1-112-SB	WES-13-1221-01	Bubbler on sink; Room 112	11.2	No
WES-1-120-SB	WES-13-1221-02	Bubbler on sink; Room 120	ND	No
WES-1-113-SB	WES-13-1221-03	Bubbler on sink; Room 113	11.1	No
WES-1-117-SB	WES-13-1221-04	Bubbler on sink; Room 117	13.8	No
WES-1-115-SB	WES-13-1221-05	Bubbler on sink; Room 115	ND	No
QC BLANK	WES-13-1221-06	DI Blank	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)
ND = None Detected; NR = Not Reported